



MINOR WORKS CERTIFICATE

CERTIFICATE No: MW3-20230808214201

This is to certify that the electrical installation at the following address complies with the requirements of BS7671:2018+A2:2022 (18th Edition)

14 foster drive  
Radford Semele, leamington spa  
CV31 1WT

The following work was carried out at the address above

*Installation of outdoor spur*

This Certificate deems the installation to be in the following condition:

SATISFACTORY

Company issuing this Certificate

Diamond Electrical Installations LTD

20 Fountain Gardens

Evesham

Worcestershire

WR111JY

01386570450

info@diamond-e-i.co.uk

CPS Enrolment No: 30509

Issued on

08/08/2023

Inspected by

Oliver

Reviewed by

Bert Diamond

A handwritten signature in black ink, appearing to read "Bert Diamond", is written over a horizontal line.

Certificate generated by electroform® certification software 2023 | www.electraform.co.uk



CERTIFICATE NO: MW3-20230808214201

MINOR ELECTRICAL WORKS CERTIFICATE - MULTI

To be used for minor electrical works on the electrical installation

DETAILS OF THE CLIENT      DETAILS OF THE INSTALLATION

Leamington blinds 89 Crown Way Leamington spa warwickshire CV327SH	☎: 01926839689 ☎: 07539051632 ✉: sales@leamingtonblinds.co.uk 👤: Leamington blinds	- 14 foster drive Radford Semele, leamington spa - CV31 1WT	☎: - ☎: - ✉: - 👤: -
--	---	---	------------------------------

DESCRIPTION OF THE MINOR WORKS

<b>Description of the Minor Works</b> Installation of outdoor spur	<b>System type</b> <input checked="" type="checkbox"/> TN-C-S <input type="checkbox"/> TN-S <input type="checkbox"/> TN-C <input type="checkbox"/> TT <input type="checkbox"/> IT
	<b>Ze/Zdb (Ω)</b> <b>PFC at DB (kA)</b> 0.095      2.5
	<b>Method of protection</b> ADS

COMMENTS - DEPARTURES AND PERMITTED EXCEPTIONS

**Comments on the existing installation (Reg 644.1.2) - Details of departures and permitted exceptions from BS 7671:2018 for the altered or extended circuit (Regs 120.3, 133.1.3, 133.5).**    Risk assessment included.

-

BOARD - CIRCUIT DETAILS & ESSENTIAL TESTS

SPD functionality confirmed	N/A	Earthing conductor	<input checked="" type="checkbox"/>	Water	<input checked="" type="checkbox"/>	Gas	<input checked="" type="checkbox"/>
Oil	N/A	Structural steel	N/A	Other	NA		

DB Designation		Conductors			Overcurrent device			RCD		Ring final impedances				At least one column to be completed		Insulation resistance		RCD		AFDD		
Cct No	Circuit Designation	Live mm <sup>2</sup>	cpc mm <sup>2</sup>	Dis Time	BSEN	Rating A	Fault current	IΔn mA	RCD Type	Max Zs	r1 Ω	r <sub>n</sub> Ω	r2 Ω	R1+R2 Ω	R2 Ω	L / L MΩ	L / E MΩ	Zs Ω	Polarity	RCD IΔn ms	RCD test button	AFDD test button
1	Ring final	2.5	1.5	0.4	60898-B	32	6	-	-	1.37	0.39	0.39	0.97	0.23	-	500	500	0.36	✓	135.6	✓	N/A

TEST INSTRUMENTS USED ON THIS CERTIFICATE

<b>Multifunction</b>	-	<b>Continuity</b>	-	<b>Insulation</b>	-	<b>EFLI</b>	-	<b>RCD</b>	-
----------------------	---	-------------------	---	-------------------	---	-------------	---	------------	---

DECLARATION

I certify that the work covered by this certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations) and that to the best of my knowledge and belief, at the time of my inspection, complied with BS 7671 except as detailed in the Departures section above.

<b>Diamond Electrical Installations LTD</b> 20 Fountain Gardens Evesham Worcestershire WR111JY	☎: 01386570450 ☎: 07845454510 ✉: info@diamond-e-i.co.uk 🌐: diamond-e-i.co.uk Registration no: 30509	
--	---	--

<b>Inspected and tested by</b>		<b>Certificate authorised by</b>	
Name	Signature	Name	Signature
Oliver		Bert Diamond	
Position	Date	Position	Date
Barber	08/08/2023	Electrical Engineer	08/08/2023

**MINOR WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS**

**This CERTIFICATE is an important and valuable document which should be retained for future reference.**

- This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.
- You should have received a Certificate without watermarks and the person that issued the Certificate should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. This Certificate is not appropriate if you requested the person that issued the Certificate to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.
- This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of BS 7671 at the time the Certificate was issued.
- For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work.
- Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturers instructions should be followed with respect to test button operation.
- Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturers information. If the indication shows the device is not operational, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

Certificate produced by electraform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)