

# rainbow blinds&fabrics

61 Canyon Road, Excelsior Park  
Wishaw, Lanarkshire ML2 0EG  
01698 351888  
01698 351999

[contracts@rainbow-blinds.com](mailto:contracts@rainbow-blinds.com)

[www.rainbow-blinds-and-interiors.co.uk](http://www.rainbow-blinds-and-interiors.co.uk)

PSSD  
NHS Lanarkshire,  
Law House,  
Airdrie Road,  
Carluke.  
ML8 5EP.

14/07/2020

For the attention of: Mr Joe Dowds:

**Ref: EFA – issued 11<sup>th</sup> March 2019 – Anti-Ligature Assessment and load test – Wards 19&20  
Hairmyres Hospital:**

Dear Sir

Further to our site visit to carry out the anti-ligature load test and assessment of the privacy tracks and window curtain tracks and blinds installed within the above wards on Tuesday 30<sup>th</sup> June 2020.

The load test was carried out in accordance to EFA/2019/003 and all components were assessed for security and damage, also to confirm they were installed as per the manufacturers written instructions.

All other assessments should be carried out by the organization responsible for the overall patient health and wellbeing and should form an internal part of their safety risk management assessment.

**Ward 19:**

Interview room 1:

2 no. Kestrel KR20CF crank operated roller blinds

Blind 1 (left) not in room

Blind 2 (right) vertical load test 18kg angled 17kg all fixings in good order.

Interview Room 2:

1 no. Kestrel KR20CF crank operated roller blind.

Vertical load test 21kg angled load test 12kg

All fixings in good order.

Sensory Room:

1 no. Kestrel KR20CF crank operated roller blind